



NOTES:

1. SERVICE SADDLES ALLOWED ON EXISTING SEWER MAINS ONLY. MANUFACTURED TEE FITTINGS SHALL BE USED ON ALL NEW MAINLINES.
2. THE TAP SHALL NOT BE MADE EXCEPT IN THE PRESENCE OF A CITY INSPECTOR; NOR SHALL ANY CONNECTION BE MADE WITHOUT CITY APPROVAL.
3. CENTERLINE OF TAP SHALL BE ABOVE SPRINGLINE.
4. HOLE IN MAIN SHALL BE CORE DRILLED



**DETAIL FOR
SERVICE SADDLE CONNECTION
TO EXISTING SEWER**

DATE: AUGUST 2022	DRAWING NO. 25
----------------------	--------------------------