



SECTION A-A

NOTES:

- 1) CONTACT THE US POSTAL SERVICE FOR LOCATION OF MAILBOX UNITS. LOCATION SUBJECT TO APPROVAL BY THE CITY.
- 2) PROVIDE AN UNOBSTRUCTED ACCESS PAD MEASURING NOT LESS THAN 6' WIDE BY 6' LONG CENTERED ON THE MAILBOX UNIT. ADJACENT SIDEWALKS MAY BE USED IN MEASURING THE AREA OF THE ACCESS PAD.
- 3) WHEN LOCATED WITHIN A PLANTER STRIP, CONCRETE PAD SHALL EXTEND FROM THE BACK OF CURB TO EDGE OF SIDEWALK.
- 4) ALL ACCESS PAD SLOPES SHALL BE DESIGNED AT 1.5% MAX., IN ANY DIRECTION CONSTRUCTION NOT TO EXCEED 2% IN ANY DIRECTION.
- 5) MAILBOX UNITS SHALL BE CONNECTED BY A CONTINUOUS ACCESSIBLE WAY TO A CURB RAMP LOCATED NO GREATER THAN 50' AWAY AS MEASURED FROM THE CENTER OF THE CURB RAMP TO THE CENTER FACE OF THE FURTHEST UNIT.
- 6) CONCRETE SHALL HAVE A 28 DAY ULTIMATE COMPRESSIVE STRENGTH OF 3300 PSI.
- 7) ALL WORK SHALL COMPLY WITH CURRENT PROWAG GUIDELINES AND THE CURRENT EDITION OF OREGON STANDARD SPECIFICATIONS FOR CONSTRUCTION.

**City of  
McMinnville**

DETAIL FOR  
CLUSTERED MAILBOX UNITS

DATE: AUGUST 2022

DRAWING NO. 35